

Performance Certificate

DATE	12-05-1994	STANDARD CALIBRATION			SPECIAL CALIBRATION	
MODEL	374	% FSPR	RUN 1	RUN 2		
SERIAL NO.	219944					
REFERENCE	3745CK5AX990					
INPUT	28 VDC					
OUTPUT	4-20 mA					
FSPR	0 TO 50 "WCD					
FULL SCALE PRESSURE RANGE						
WIRING CONNECTIONS						
+ INPUT						
- INPUT						
+ OUTPUT						
- OUTPUT						
PIN A	+PWR./SIG.					
PIN B	-PWR./SIG.					
PIN C	CALIBRATE					
PIN D	CALIBRATE					
PINS E+F	NO CONN.					

FIELD CALIBRATION PRESSURE= 40.125 "WCD

CALIBRATION CIRCUIT

An advantage of Viatran strain gage pressure sensors is that the gain or span of the readout system can be set without applying a known pressure input. The system setup can be accomplished by using a calibrate circuit as explained below.

INTERNAL CIRCUIT

Most sensor models are supplied with an internal shunt calibrate circuit either as a standard or by special order. If this sensor has the circuit included, it will be noted below. Simply shorting the proper pins will produce the calibration output signal listed.

EXTERNAL CIRCUIT

If the sensor does not include the calibration circuit, the same type calibration can be accomplished by connecting a resistor of the value indicated across the proper pins. This technique is accurate for cable lengths of up to 200 ft.

☒ Transducer - Internal Calibration
Shorting pins C & D will produce
a 16.85 mA calibration output signal.

☐ Transducer - External Calibration
Connecting ohms across
pins & will produce
a calibration output signal.

☐ Transmitter* - Internal Calibration Circuit and Switch
Cal 1 represents with a reading
of
Cal 2 represents with a reading
of

NOTE: All calibrations should be performed only after the transducer has been adjusted for zero at zero pressure.

* See detailed instructions shipped with each unit.

WARRANTY

Viatran Corporation warrants that its products shall be free from defective part and workmanship for a period of twelve (12) months from date of original shipment provided that Viatran's obligation hereunder shall be limited to correcting any defective workmanship and/or replacing any defective material F.O.B. destination.

A repair is warranted ninety (90) days from repair date under conditions of original warranty period unless superseded by original warranty period. If inspection by the Company of such product does not disclose any defect of workmanship or material, the Company's regular charges will apply. This warranty carries no liability, either expressed or implied, beyond our obligation to replace the unit which carries the warranty. This warranty is in lieu of all other warranties of merchantability or fitness. No allowance will be made for any expense incurred for correcting any defective workmanship and/or material without written consent by Viatran. Unit must be shipped to the Company, transportation prepaid, and return authorization number must be referenced on the package to assure acceptance at our shipping dock. Prices specifications and decisions subject to change without notice.

The Company shall not be liable for and the Purchaser assumes and agrees to indemnify and save harmless the Company in respect to any loss or damage that may arise through the use by the Purchaser, or others, of any of the Company's products.

This warranty is void if the product is subjected to misuse, accident, neglect or improper application, installation or operation. This warranty is void if prior defects in materials or workmanship repairs are made by anyone except Viatran or its authorized service agency.

REPAIR

Most Viatran sensors have been designed to be easily repaired and recalibrated necessary. If a failure occurs, the sensor should be returned to the factory for inspection and testing. If the sensor failure is covered by our one year warranty policy, the unit will be repaired as necessary and reshipped without delay. Sensors usually not covered by warranty can be repaired within four to six weeks for approximately thirty to sixty percent of the purchase price. Simple repairs can often be made for minimum charge. Units should be returned to the attention of the Repair Department, after obtaining return authorization number from the customer service desk at (716) 773-1700.

QUALITY ASSURANCE

Viatran CORPORATION
300 INDUSTRIAL DRIVE
GRAND ISLAND
NEW YORK 14072
PHONE 716 773 1700 • FAX 716 773 2488

SCOTT BRINSER

Q.A.A.

SB.
12/06/94